

Gill's Heating and Cooling Inc.

122 E. Crystal Ave. Lake Wales. FL, 33853

PHONE: 863-638-4455 FAX: 863-676-5166

LIC.CAC057929

CITY OF LAKE WALES (DREW BUCKNER)
201 W CENTRAL AVE.
LAKE WALES FL, 33853

DATE: 3/16/2020
JOB: YMCA

*I went and check the site with Mike at YMCA and found list below.
Found 3 big air handlers that need to be cleaned and belts replaced.
Lobby-Carrier--M-40RMQ016-B610HC--- Serial--3900F34461 year-2000 (Needs replaced).
Auditorium-Carrier- FAS180MAAA0A0A--- Serial--U151210183 Year-2012
(Water in pan, belt and clean).
Bath/Gym Rheem-RHGG-180ZL--- Serial--212F260804767 year-2008 (Belt and clean).
Ductless has freon leak/ needed cleaned or replaced.
Kitchen- rusted out metal and air handlers 11 years old (should replace air handlers and stands)
Water all over the place.
Kids Room-5 ton needed clean and UV light. ARUF061-00A-1A--serial-0506154981 year2005*

*Replace 3- 2.5ton Bard wall hung and 1-3 ton.
Clean coil and install Uv light in kids air handler.
Clean coils and replace belts on 3 big air handlers.
Replace 2 ton ductless.
Replace 2-5ton air handlers and stands for kitchen units.
Replaced 15ton air handler due to condition.*

Materials---\$22,141
Markup----\$ 6,200
Labor-----\$ 8659
Total-----\$37,000

*Thank you for allowing us the opportunity to submit our proposal. If you have any questions,
please feel free to call at any time.*

Sincerely,

Joe Gill
863-287-6445

Acceptance----- Date-----